

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-1130:219

Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Honeywell International Inc., 1500 West Dundee Road, Arlington Heights, IL 60004  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Models XLSG4-S2, XLSG4R-S2, XLSG4-S7, XLSG4R-S7, \*XLSG4F-S7, \*XLSG4RF-S7, \*XLSG4F-S2 and \*XLSG4RF-S2 speakers.  
Models XLSG4-S2VM, XLSG4R-S2VM, XLSG4-S7VM, XLSG4R-S7VM, \*XLSG4F-S2VM, \*XLSG4RF-S2VM, \*XLSG4F-S7VM, and \*XLSG4RF-S7VM speaker strobes.  
Models XLSG4B and XLSG4RB speaker enclosure backbox. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 25 Vrms or 70 Vrms  
¼ W, ½ W, 1 W, 2 W  
Candela: 15cd, 30cd, 75cd, 110cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, Model number, electrical rating, UL label.

**APPROVAL:** Listed as speakers and speaker/strobes for use with separately listed compatible control unit. Speakers with a strobe are suitable for the hearing impaired. For indoor use only.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLF:** \*7320-1591:211 Formerly 7320-1388:243

\*Rev. 07-30-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 30, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager